

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19157

1. OWNER Gary Lane ADDRESS AT WELL LOCATION.....
MAILING ADDRESS HC 34 Box 34005 Ely NV
89301
2. LOCATION S/E $\frac{1}{4}$ S/W $\frac{1}{4}$ Sec. 30 T. 12 N. S. R. 61 E. White pine County
PERMIT NO. 0 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	3	3
Sand- boulders		3	9	6
Uplandic Boulders		9	91	82
Cemented Gravel		91	100	9
Coarse sand	✓	100	104	4
Cemented Gravel	✓	104	130	26
Coarse sand		130	136	6
Cemented gravel	✓	136	155	19
Coarse gravel	✓	155	162	7
Clay- gravel		162	165	3
Clay		162	167	5

TD 167

8. WELL CONSTRUCTION
Depth Drilled 167 Feet Depth Cased 167 Feet
HOLE DIAMETER (BIT SIZE)
From 10 5/8 Inches To 167 Feet
Inches..... Feet..... Feet
Inches..... Feet..... Feet
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>0</u>	<u>167</u>

Perforations:
Type perforation factory
Size perforation 18" x 3"
From 107 feet to 167 feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 167 feet

RECEIVED
APR 24 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 04-8-95, 19.....
Date completed 04-12-95, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>100</u>	<u>0</u>	<u>1</u>

9. WATER LEVEL
Static water level 67 feet below land surface
Artesian flow 0 G.P.M. 0 P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling Contractor
Address P.O. Box 54 Contractor
Hiko Nev. 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis
By-driller performing actual drilling on site or contractor
Date 5/9/95