

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28868
Big Wash Canyon

1. OWNER Ronald & Robin Crouch ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Box 428
St. George, UT 84271

2. LOCATION SW 1/4 SE 1/4 Sec. 28 T. 12 N. R. 70 E. White Pine County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Gravel		5	30	25
Clay & Gravel		30	40	10
Water Bearing Gravel	x	40	45	5
Sedimentary Gravel & Clay		45	155	110
Clay		155	160	5
Sedimentary Gravel & Clay		160	245	85
Sand Gravel & Clay	x	245		
Water Bearing Seam			289	44

8. WELL CONSTRUCTION
 Depth Drilled 289 Feet Depth Cased 289 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 289 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	289

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 109 feet to 289 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 289 feet

RECEIVED
 25 SEP - 5 PM 2:27
 STATE ENGINEERS OFFICE

Date started August 16, 19.95
 Date completed August 22, 19.95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3	253	3

9. WATER LEVEL
 Static water level 27 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nv 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed August 24, 1995
 By driller performing actual drilling on site or contractor
 Date James D. Christiansen