WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67897
Permit No.
Basin 195

NOTICE OF INTENT NO. 29696

1. OWNER Ronald and Robin Crouch
MAILING ADDRESS P.P. Box 66
Baker, Nevada 89311

ADDRESS AT WELL LOCATION
Sec 34 T 12 N/S R 70
2000 Big Wash Road

2. LOCATION ¼ ¼ Sec 34 T 12 N/S R 70 E White Pine County
PERMIT NO. N/A Issued by Water Resources | N/A Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black top soil		0	1	1 ft
Tan clay		1	5	4 ft
Gravel		5	8	3 ft
Tan clay		8	13	5 ft
Gravel		13	14	1 ft
Clay		14	40	26 ft
Gravel	64-69	40	69	29 ft
Limestone	105 ft	69	120	51 ft

Date started December 14, 19 96
Date completed June 2, 19 97

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
21	10 ft 6 in	6 hours

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	28.55	.320	0	120

Perforations:
Type perforation mills [redacted]
Size perforation ¼ inch by 2 inch
From 104 feet to 109 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 52ft 3 inches feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 51 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name George Douglass
Contractor
Address HC 61 Box 380 Wendover Ut 84083
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0041559
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2014
Signed George Douglass
By driller performing actual drilling on site or contractor
Date 7 June 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627