WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84260
Permit No. 67334
Basin 212

NOTICE OF INTENT NO. 22136

1. OWNER Clark Thomas John & Debbie J Clark
MAILING ADDRESS 5240 Styers St.
North Las Vegas, NV 89031-2005

ADDRESS AT WELL LOCATION 5220 Styers St.
North Las Vegas, NV

2. LOCATION SW ¼ NE ¼ Sec. 31 T 19 N/S R 61 E County
PERMIT NO. 67334 (Issued by Water Resources) | 124-31-602-023 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty clay		0	180	180
Popcorn caliche	x			
Silty clay	x	180	203	23
Silty clay		230	278	75
Brown clay with gravel layers	xx	228	355	
Sandy silt and gravel	x	355	405	50

Date started 9/18/01, 19
Date completed 9/20/01, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	80		1 hr.

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	50	Feet
10	Inches	50	Feet	405	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	12.96	.188	-1	405

Perforations:
Type perforation 1/4" x 6" 4 around
Size perforation Torch
From 185 feet to 405 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [XX] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [XX] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 107 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. Valley View Blvd. (Contractor)
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301

Signed Fred B. Allen II
By driller performing actual drilling on site or contractor

Date September 20, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627